

# Aaron Equipment Company

STOCK# 48363001 TYPE: SPIRAL HEAT EXC. SER:# 18736

Hydro TEST: X DATE: 9/14/16 TECHNICIAN: D. RODRIGUEZ

vessel Tag 75PSF

Test: @ 117 PSI start time: 2pm finish time: 4pm

PSI @ 15 min: 117 @ 30min: 117 @45min: 117 @60min: 117

@ 75 min: 117 @ 90min: 117 @ 105min: 117 @ 120min: 117

Condition of JACKET: good  fair  bad  Rotary joint: Y or  N

Condition of inlets: good  fair  bad

Comments

---

---

---

---

---

Technician: Sig. 

Witness: Sig. 